



GARNET ENERGY CENTER

Case No. 20-F-0043

1001.34 Exhibit 34

Electric Interconnection

Contents

Exhibit 34: Electric Interconnection	1
34(a) Voltage	1
34(b) Conductors	1
34(c) Insulator Design	2
34(d) Length of Transmission Line	2
34(e) Tower Dimensions & Construction Materials	2
34(f) Tower Design Standards	2
34(g) Underground Cable System & Design Standards	5
34(h) Underground Lines Profile & Oil Pumping Stations/Manhole Locations	5
34(i) Equipment to be Installed	5
34(j) Any Terminal Facility	5
34(k) Cathodic Protection Measures	5
34(l) Collection Lines	6
34(m) Visual Impacts	6

Tables

Table 34-1. Tower Design Standards	2
--	---

Exhibit 34: Electric Interconnection

This Exhibit will track the requirements of Final Stipulation 34, dated March 5, 2021, and therefore, the requirements of 16 New York Codes, Rules and Regulations (NYCRR) §1001.34. The solar power generated by the Project will be connected into the existing transmission grid from low voltage to high voltage using a collection cable system and rigid bus interconnected to the proposed Point of Interconnection (POI) switchyard, to be transferred to New York Power Authority (NYPA) to own and operate. The solar panels will generate power at a low voltage, which will be converted from direct current (DC) to alternating current (AC) at the inverters and stepped up to medium voltage at pad-mount transformers that are connected to the inverters. Medium voltage will be collected by a system comprised of underground cables, which will transmit power to the proposed, on-site collection substation. The collection substation will transform the power up to 345 kilovolts (kV) and will deliver the power to the POI switchyard. The Project will interconnect to the New York electric transmission system by connecting to NYPA's existing Clay-Pannell 345 kV transmission line as described below, to be located within the Project Area.

34(a) Voltage

The medium voltage collection lines will have a nominal voltage of 34.5 kV from line to line, with a maximum design level voltage of 38 kV. The 34.5 kV collection lines within the Project Area will gather power from the inverters and transport it underground to the collection substation. The collection substation transformer will step up the voltage to 345 kV and then transport power to an immediately adjacent POI switchyard that will then interconnect to the existing Clay-Pannell 345 kV transmission line.

34(b) Conductors

The conductors associated with the two 345 kV transmission lines are 795 kilo-circular mil (KCMIL) aluminum conductor steel reinforced (ACSR) 26/7 "Drake." The Project will use three 1590 KCMIL 61 all aluminum conductor (AAC) and two 795 KCMIL 26/7 ACSR cable systems.

The conductors originating within the collection substation fence consist of either flexible strain conductor or rigid bus for the connection between the substation and interconnecting to the POI switchyard with the Clay-Pannell 345 kV line. The rigid bus will be 5" Schedule 80 Aluminum

Tube. Transformer conductor leads will be two 795 KCMIL AAC on the low voltage side of the power transformer and three 1590 KCMIL AAC on the high voltage side.

The conductors for the 34.5 kV underground collector cable terminators and surge arresters will be 1272KCM AAC and 336KCM AAC, respectively.

34(c) Insulator Design

The insulators for the rigid bus system and disconnect switches will be porcelain station post and will be American National Standards Institute (ANSI) 70 gray. The load of the insulator shall not exceed the respective insulator strength published in ANSI C29.9, Tables 1 and 2.

34(d) Length of Transmission Line

The new transmission line for the Project consists of two transmission lines of approximately 207 feet and 563 feet, respectively, which will interconnect with the southern existing single circuit overhead NYPA 345 kV Clay-Pannell line.

34(e) Tower Dimensions & Construction Materials

The Project proposes the use of steel pole towers. The steel structures will be approximately 50 feet to 140 feet above ground depending on the location and will utilize a three-phase configuration (see Appendix 11-1, Preliminary Design Drawings). The diameter of the steel pole towers will also be approximately 7 feet.

34(f) Tower Design Standards

The design standards for proposed towers and tower foundations are provided in Table 34-1, below.

Table 34-1. Tower Design Standards

Standard	Name
ANSI/AWS D1.1	Structural Welding Code
ANSI C2-2017	2017 National Electrical Safety Code (NESC)
ASCE 48	Design of Steel Transmission Pole Structures
ASTM A36	Structural Steel
ASTM A123	Specification for Zinc (Hot Dip Galvanized) Coatings on Iron and Steel Products

Table 34-1. Tower Design Standards

Standard	Name
ASTM A143	Standard Practice for Safeguarding Against Embrittlement of Hot-Dip Galvanized Structural Steel Products and Procedure for Detecting Embrittlement
ASTM A153	Standard Specification for Zinc Coating (Hot-Dip) on Iron and Steel Hardware
ASTM A276	Standard Specification for Stainless Steel Bars and Shapes
ASTM A325	Standard Specification for Structural Bolts, Steel, Heat Treated, 120/105 ksi Minimum Tensile Strength
ASTM A354	Standard Specification for Quenched and Tempered Alloy Steel Bolts, Studs, and Other Externally Threaded Fasteners
ASTM A370	Standard Test Methods and Definitions for Mechanical Testing of Steel Products
ASTM A384	Standard Practice for Safeguarding Against Warpage and Distortion During Hot-Dip Galvanizing of Steel Assemblies
ASTM A435	Standard Specification for Straight-Beam Ultrasonic Examination of Steel Plates
ASTM A490	Standard Specification for Structural Bolts, Alloy Steel, Heat Treated, 150 ksi Minimum Tensile Strength
ASTM A572	Standard Specification for High-Strength Low-Alloy Columbium-Vanadium Structural Steel
ASTM A615	Standard Specification for Deformed and Plain Carbon-Steel Bars for Concrete Reinforcement
ASTM A673	Standard Specification for Sampling Procedure for Impact Testing of Structural Steel
ASTM A767	Standard Specification for Zinc Coated Steel Bars for Concrete Reinforcement
SSPC-SP 6	Commercial Blast Cleaning
ACI 117	Specification for Tolerances for Concrete Construction and Materials (AC/ 117-10) and Commentary
ACI 211.1	Standard Practice for Selecting Proportions for Normal, Heavyweight, and Mass Concrete
ACI 301	Specifications for Structural Concrete
ACI 305.1	Specification for Hot Weather Concreting
ACI 306.1	Standard Specifications for Cold Weather Concreting
ACI 336.1	Specification for the Construction of Drilled Piers
ASTM C31	Standard Practice for Making and Curing Concrete Test Specimens in the Field
ASTM C33	Standard Specification for Concrete Aggregates

Table 34-1. Tower Design Standards

Standard	Name
ASTM C39	Standard Test Method for Compressive Strength of Cylindrical Concrete Specimens
ASTM C94	Standard Specification for Ready-Mixed Concrete
ASTM C150	Standard Specification for Portland Cement
ASTM C171	Standard Specification for Sheet Materials for Curing Concrete
ASTM C172	Standard Practice for Sampling Freshly Mixed Concrete
ASTM C231	Standard Test Method for Air Content of Freshly Mixed Concrete by the Pressure Method
ASTM C233	Standard Test Method for Air-Entraining Admixtures for Concrete
ASTM C260	Standard Specification for Air-Entraining Admixtures for Concrete
ASTM C309	Standard Specification for Liquid Membrane-Forming Compounds for Curing Concrete
ASTM C403	Standard Test Method for Time of Setting of Concrete Mixtures by Penetration Resistance
ASTM C494	Standard Specification for Chemical Admixtures for Concrete
ASTM C617	Standard Practice for Capping Cylindrical Concrete Specimens
ASTM C618	Standard Specification for Coal Fly Ash and Raw or Calcined Natural Pozzolan for Use in Concrete
ASTM C1064	Standard Test Method for Temperature of Freshly Mixed Hydraulic-Cement Concrete
ASTM C1107	Standard Specification for Packaged Dry, Hydraulic Cement Grout (Nonshrink)
ASTM C1260	Standard Test Method for Potential Alkali Reactivity of Aggregates (Mortar-Bar Method)
ASTM C1567	Standard Test Method for Determining the Potential Alkali-Silica Reactivity of Combinations of Cementitious Materials and Aggregate (Accelerated Mortar-Bar Method)
ASTM D698	Standard Test Methods for Laboratory Compaction Characteristics of Soil Using Standard Effort
ASTM E329	Standard Specification for Agencies Engaged in Construction Inspection, Testing, or Special Inspection
API RP 13B-1	Recommended Practice for Field Testing Water-Based Drilling Fluids
ACI: American Concrete Institute ASCE: American Society of Civil Engineers ANSI: American National Standards Institute AWS: American Welding Society ASTM: American Society for Testing and Materials SSPC: Society for Protective Coatings API: American Petroleum Institute	

34(g) Underground Cable System & Design Standards

Power produced by the solar array will be collected by the underground collector systems described in Sections 34(a) and 34(b). Collection cables will be designed in accordance with the following standards:

- Insulated Cable Engineers Association (ICEA) S-93-639
- Association of Edison Illuminating Companies (AEIC) CS8

34(h) Underground Lines Profile & Oil Pumping Stations/Manhole Locations

The underground collection lines and associated material are portrayed in Appendix 11-1. The cable will be buried at varying depths, depending on the location and environmental conditions, but generally no less than 36 inches outside of agricultural lands and 48 inches within agricultural lands.

Oil pumping stations and manhole locations will not be utilized as part of the 34.5 kV collection system. This is typical of pipe-type cable installation.

34(i) Equipment to be Installed

The collector substation will include 34.5 kV busses, power transformers, circuit breakers, instrument transformer and revenue metering, air-break disconnect switches, steel structures, and a control room (a non-habitable equipment structure). The 345-kV switchyard will also include similar equipment. These components are necessary for delivery of energy produced by the Project to the existing electrical power grid.

All required equipment and structures within the switchyard will be designed in accordance with the requirements of NYPA, the transmission operator and owner of the existing Clay-Pannell line.

34(j) Any Terminal Facility

The terminal facilities for the Project consist of the collection substation and POI switchyard, both as described above.

34(k) Cathodic Protection Measures

Cathodic protection measures are not expected to be required on the underground portion (collection system) or for the steel poles (overhead 345 kV interconnection) for the Project. An alternating current interference study will be performed as part of the crossing agreement with

National Fuel for the Project's proposed crossings of the Empire Pipeline with any underground collection and overhead interconnection lines. If the analysis determines that cathodic protection is required, it will be designed in accordance with applicable standards.

34(l) Collection Lines

The collection system for the Project will be installed underground primarily by cable plow and some open trenching. Horizontal directional drilling (HDD) may be utilized in select locations to avoid impacts to existing roadways and environmentally sensitive areas as necessary. The location and extent of HDD activities for the Project are further described in Exhibit 21. A conceptual layout of the cable collection system will also be provided in the Preliminary Design Drawings. In addition, a detail of typical medium voltage underground trenching is shown in the Construction Details. Overhead collection lines are not proposed for the Project. As noted above, overhead lines are proposed for the transmission lines, connecting the collection substation to the POI switchyard and then the existing NYPA line for a span of approximately 207 feet and 563 feet, respectively. The overhead lines have been sited adjacent to a proposed array in an area that will not be utilized for agricultural purposes during operation of the Project. The transmission pole structures will be located between the POI switchyard and the Clay-Pannell transmission line and will not interfere with any agricultural practices.

34(m) Visual Impacts

Overhead transmission pole structures proposed have been incorporated in the Visual Impact Assessment, as discussed in Exhibit 24.